

City of Paducah, Kentucky

Engineering Department

**“CLEMENTS ST – FARLEY PLACE SIDEWALK PROJECT”**

**ADDENDUM NO. 2**

**May 28, 2026**

This document is an Amendment of the Plans and Specifications for “CLEMENTS ST – FARLEY PLACE SIDEWALK PROJECT” and shall be a part of and included in the Contract. When the Addendum conflicts with the original Specifications and/or Drawings, this Addendum shall govern.

**Pre-bid meeting questions:**

- Straw will NOT be allowed in the ROW, excelsior matting must be used with backfill and seeding.
- Reconstructed sidewalk elevation will be based off the existing curb and gutter.
- The only curb and gutter will be adjacent to handicap ramps.
- Entrance will only be replaced at the back of the entrance at a 2% grade.
- Backfill for entrance will be an in-kind repair.
- No drain boxes to be replaced.
- City will handle fences outside this contract.
- No trees will be impacted.
- Asphalt cut and patch will be incidental.
- Project is funded with CDBG funds requiring Prevailing Wages, weekly certified payrolls, and Buy America Build America requirements.
- Federal funds require a project board with all the federal required postings
- The project must be completed by August 31, 2026, due to funding requirements.
- Total project funding will be shared with the accepted bidder after award of contract.

**Confirmation:** Bidders shall Acknowledge Receipt of this Addendum by signing the last sheet of this Addendum and returning to this office via e-mail at [mtownsend@paducahky.gov](mailto:mtownsend@paducahky.gov)

City of Paducah

\_\_\_\_\_  
Greg Guebert, P.E.  
City Engineer

**CONFIRMATION**

**BIDDERS shall Acknowledge Receipt of This Addendum by Signing below and returning to this office via e-mail [mtownsend@paducahky.gov](mailto:mtownsend@paducahky.gov).**

BIDDER: \_\_\_\_\_

BY: \_\_\_\_\_ DATE: \_\_\_\_\_

TITLE: \_\_\_\_\_